

Addendum No. 1

Find yourself in good company

Project Name:	Jaycee Park Administration Building	Project No.:	PC-0019
	Roof Replacement		
Meeting Location:	Jaycee Park Administration Building	Meeting Date:	Tuesday, June 20, 2017
	2000 Cedar Lane		@ 9:00 AM
	Greenville, NC		
Prepared By:	Mike Watson	Date:	June 23, 2017

ATTENDEES:					
Name	Company	Phone No.	E-mail Address		
Mike Watson	City of Greenville	252-329-4539	mwatson@greenvillenc.gov		
Denisha Harris	City of Greenville	252-329-4862	dharris@greenvillenc.gov		
Ferdinand Rouse	City of Greenville	252-329-4462	frouse@greenvillenc.gov		
Jeff Bell	The Davis Co.	252-217-8382	Davisco5555@gmail.com		
Brady Knowles	Owens Roofing Inc.	919-821-0082	brady@owensroofinginc.com		
Char Harper	Curtis Construction Co.	252-398-5046	chad@curtiscc.com		
Will Trute	Allied Roofing Co. Inc	336-409-7093	wtrute@alliedrfg.com		
Justin Dries	Team Craft Roofing	919-538-3999	Justin.dries@tcrfg.com		
Brad Shaltz	Triangle Roofing Services	919-269-8882	brad@triangleroof.com		
David Tedder	DLT Roofing, Inc.	919-284-5800	dltroofing@yahoo.com		
Patrick Lawrence	Roofers Supply, Inc.	919-607-2988	patrick@rooferssupplyinc.com		

Clarifications & Requirements

- 1. Acknowledgement of all addenda received must be noted on the bid submittal form. Any and all addenda shall become part of the specifications and the bid package for the project.
- 2. Any contractor who attended the mandatory pre-bid meeting can make arrangements to visit the site at any time up until the bids are due. This is allowed due to the weather the day of the pre-bid meeting.
- 3. On page 5, section 7.0, delete this section. The Local Preference Policy will not be applicable for this project.
- 4. On page 14, section 2.1.A.1, delete all references to the Garland Company and Commercial Innovations. Products by Seaman Corporation will be the only manufacture allowed for this project.
- 5. On the roof replacement completed in 2015, it appears that the minimum insulation thickness of the ISO at the drains was 1/2". There was a 1/2" dexcell gypsum cover board on top, so total insulation thickness at the drains was 1" The insulation system is sloped to provide drainage over the flat roof deck
- 6. The scheduled timeline for completion of the project will be by September 29, 2017.

COG 1054818 Page 1

Bids are due Friday, June 30, 2017 at the Jaycee Park Administration Building, 2000 Cedar Lane, Greenville, NC. Bids will be accepted up to 10:00 A.M. There will not be a public bid opening. Bids will opened by staff and a bid tabulation sheet will be available upon request once the contract is awarded to the successful bidder. *Note: Mailed proposals will be accepted up to the 10:00 A.M. deadline. All proposals received in the mail will be stamped with the date and time or receipt.*

COG 1054818 Page 2