

### Addendum No. 1

Project Name:	Lucille W Gorham Intergenerational Center	Project No.:	BFC-0176
Meeting Location:	110 Ward Street Greenville, NC 27834	Pre-Bid Meeting Date:	Thursday, November 03, 2016 @10:00 AM
Prepared By:	Ross Peterson	Date:	November 03, 2016

ATTENDEES:						
Name	Company	Phone No.	E-mail Address			
Ross Peterson	City of Greenville	252-329-4921	rpeterson@greenvillenc.gov			
Devin Thompson	City of Greenville	252-329-4931	dthompson@greenvillenc.gov			
Barry Byrd	Etheridge Roofing	252-291-5200	barryb@etheridgeroofing.com			
David Tedder	DLT Roofing Inc	919-284-5800	dltroofing@yahoo.com			
Barry Sugg	Service Roofing and Siding	252-758-2179	bsugg@serviceroofing.com			
Chad Harper	Curtis Construction	252-378-5046	chad@curtiscc.com			
Taylor Dyer	Baker Roofing	252-375-0858	tdver@bakerroofing.com			
Gary Kurth	AAR Roofing	336-727-4534	garyk@aarnc.com			

# Site Visit – November 3, 2016

- 1. A site visit was conducted immediately after the Pre-bid meeting was completed.
- 2. Access to view the area of work for a visual inspection, layout and discussion of work to be completed was held.

## **Clarifications & Requirements**

- 1. Acknowledgement of all addenda received must be noted on the bid submittal form. Any and all addendums shall become part of the specifications and the bid package for the project
- 2. Full tear off of existing roof
- 3. Contractor that is awarded bid must provide a design submittal emailed to Ross Peterson, Building Facilities Coordinator at <u>rpeterson@greenvillenc.gov</u>
- 4. Metal trim can be formed at your shop
- 5. Two sets of close out documents required in a book and CD
- 6. Chimney metal and flashing to match existing color
- 7. All known contaminated material must be double bagged and dispose of properly with proper manifest provided to the City of Greenville
- 8. All roof penetrations (vents) must be above 8" of roofing membrane
- 9. **NO** gutters or downspouts will be replaced

Bids are due Thursday, November 17, 2016 at the Public Works Building, 1500 Beatty Street, Greenville, NC. Bids will be accepted up to 2:00 P.M.

End of Addendum #1

.

### City of Greenville NORTH CAROLINA PROSPECTIVE CONTRACTOR DATA FORM

Company Name:		
Address:		
	Mobile Phone Number:	
Email:	Business Fax Number:	
Tax ID#		·····
Corporation or Partnership:		
Number of Years in Business:		

### CITY OF GREENVILLE PUBLIC WORKS DEPARTMENT REQUEST FOR BIDS

In compliance with the request for bids by the City of Greenville and subject to all conditions and specifications thereof, the undersigned offers and agrees to furnish all equipment, labor and work site clean-up as provided in the above mentioned specifications.

#### **Description**

Lucille W Gorham Intergeneration Center Roof Replacement-EPDM roof system

Lump Sum Bid Total	\$
Addendum Acknowledgment	 
Please record each addendum item received	 
Bid reviewed, prepared and submitted by-	
Company Name:	
Signed:	
Print Name:	
Date:	