

**Adventure Park ITB  
Addendum No. 04**



<b>Project Name: Adventure Park Phase 1</b>	<b>Project No.:</b> RFQ#20-21-14
<b>Prepared By: Mark Nottingham</b>	<b>Date:</b> 9-24-2020

**Plan Clarifications:**

- The NCDOT sidewalk detail has been deleted. The only sidewalk detail on sheet C11 does not require CABC.
  
- For the handicap parking areas: use 6" of concrete, with no CABC. The dumpster pad detail can be used for reference.