

Addendum No. 1

ITB#23-24-20

Project Name:	Parking Lot Expansion Thomas Foreman Park	Project No.:	PC-0128
Prepared By:	Mike Watson	Date:	October 10, 2023

Clarifications & Requirements:

- 1. Acknowledgement of all addenda received must be noted on the bid submittal form. Any and all addenda shall become part of the specifications and the bid package for this project.
- 2. The Geotechnical Engineering Report is available upon request.
- 3. The City of Greenville will contract with a testing company to conduct a proof roll and stone density test prior to the pouring of the asphalt. The contractor shall coordinate with the City and/or the testing company for when these services are needed.
- 4. The select fill material shall be 6" of compacted ABC stone.
- 5. The construction time shall increase to January 19, 2024 if Alternate #1 is accepted as part of the contract.
- 6. The award of the project shall be based on the lowest responsive combined base and alternate bids. See page 2, paragraph 5, of the bid document for more information concerning the acceptance of bids.
- 7. Prior to bidding, if there are any concerns or issues once the work starts with roots of trees that will remain, utility lines, existing sidewalks, etc. it will be addressed as a change order.

Bids are due Thursday, October 19, 2023 via email to <u>mwatson@greenvillenc.gov</u> or mailed to the Jaycee Park Administration Building, 2000 Cedar Lane, Greenville, NC. Bids will be accepted up to 2:00 PM. There will not be a public bid opening. Bids will be opened by staff and a bid tabulation sheet will be available upon request once the contract is awarded to the successful bidder.

Attachments:

• Pre-Bid Meeting Sign-In Sheet

Page of			Bevon Whatey	Garriss Jones	Justin Petkurun	Blake Jones	Edwood FERRY
		c	8480-11-E-252 printer solution	Lawier construction	Garris	S.T. Wasten	MRY GRANINS
			- 84% 112-252	252-747-812	252-671	252-705-0925	7494