

Addendum No. 1

| | |
|-------------------------------------------|----------------------------------|
| Project Name: HVAC Replacement SML | Project No.: ITB#24-25-39 |
| Prepared By: Ross Peterson | Date: 04/24/25 |

General Questions, Clarifications & Requirements:

Acknowledgement of all addenda received must be noted on the bid submittal form. Any and all addenda shall become part of the specifications and the bid package for this project. Refer to the addendum for more information.

Question

Specification for test and balance

Answer

Refer to “Balancing” on page 4 of The East Group HVAC unit sizing evaluation report.

Notes

A new bid form is provided to include tax.

Scope 1.14 shall include 5-year parts and labor, and 10-year compressor extended warranty by Trane.

Discard number 10 on notes in Air Handler Schedule from The East Group HVAC unit sizing evaluation report for units 9-13. Units 7 and 8 call for heat pumps with electric coils.

Attachments:

Yes

End of Addendum No. 1