

Addendum No. 2

Project Name: Site & Foundation Work for Class A Burn Facility	Project No.: ITB#24-25-44
Prepared By: Ross Peterson	Date: 05/22/2025

General Questions, Clarifications & Requirements:

Acknowledgement of all addenda received must be noted on the bid submittal form. Any and all addenda shall become part of the specifications and the bid package for this project. Refer to the addendum for more information.

Question

For the structural drawings, are the GCs supplying the concrete pad with footings?

Answer

Yes, GC is responsible for all aspects of footings.

Question

Do we have anything in our scope to do anything with the containers or is Greenville taking care of that?

Answer

No, the container system is being purchased through third party that will construct system.

Question

On sheet C1.0 the lot calls for internal gravel area 6" #57 stone. On sheet S101 the engineers put a note for 6" of concrete on a granular base. With this note being on the structural drawings, I would like confirmation. Should I disregard the note on S101?

Answer

C1.0 is for site work. S101 is for the foundation work. **Yes, disregard as there is no concrete pad for this project. The site will be 57 stone with a perimeter of crusher run.**

Question

Is the fence part of the scope of work?

Answer

No

Question

Is the lighting part of the scope of work?

Answer

No

Question

Will the site be stacked for location of footers

Answer

No, location of footers will be determined by owner with contractor.

Notes

A second revision of the site drawing has been posted to website.

Site drawing and foundation drawing are separate drawings and should be reviewed thoroughly.

Attachments:

Posted on the City of Greenville website.

[Site & Foundation Work for Class A Burn Facility | Current Bid Opportunities | Greenville, NC](#)

End of Addendum No. 1