

SITE	CONTACT PERSON	HRS OF OPERATION	BUILDING ISSUES
<b>Aquatic and Fitness Center</b>	Kathleen Shank 252-329-4568	Mon.-Thur. 5:30 AM - 9:00 PM Fri. 5:30 AM - 4:00 PM Sat. 8:00 AM - 4:00 PM Sun. 1:00 PM - 6:00 PM	Pool dehumidifier and the associated air handler are at end of their functional life. Both units are major energy users & expensive pieces of equipment to replace. We have received an opinion that, when new equipment is installed, it would be possible to capture the waste heat from the dehumidifier, possibly supplement it with solar panels, and use the heat generated to heat the pool water. Gym AC being installed now (2011). Roof in very poor condition; insulation likely saturated. "The money pit".
<b>H. Boyd Lee Park</b>	Dennis Vestal 252-329-4268	Mon.-Thur. 12:00 PM - 9:00 PM Fri. 12:00 PM - 7:00 PM Sat. 10:00 AM - 2:00 PM	Hi heat gain from west facing windows in gym & other building areas Tinting & possibly awnings would have considerable merit. HVAC likely at mid-life (1999). Gym in line for AC installation next budget cycle if funded.
<b>Jaycee Park</b>	Dean Foy 252-329-4543	Mon.-Fri. 8:00 AM - 9:00 PM 9:00 AM - 3:00 PM Closed	Sat. Sun. Individual gas pack units are conking out one by one; heat exchangers & compressors. Contactors also failing. No systematic replacement program in place.
<b>Eppes</b>	Alonza Price 252-329-4196	Mon.-Fri. 9:00 AM - 9:00 PM 10:00 AM - 2:00 PM Closed	Sat. Sun. Building completely rewired & had new HVAC installed in the gym 2010. New tinted, insulated gym windows installed 2010. Old building section uses window units for cooling; very inefficient.
<b>Park Maintenance Center</b>	Steve Warner 252-329-4554	Mon.-Fri. 7:00 AM-3:00 PM	1927 vintage building. Office & assembly room cools with all window units. Work area heated with gas ceiling units. Roof has no insulation & no cooling. Metal windows losing their glazing. Highly inefficient series of buildings.
<b>South Greenville</b>	Troy Smith 252-329-4549	Mon.-Fri. 9:00 AM - 7:00 PM 10:00 AM - 2:00 PM Closed	Sat. Sun. Gas pack units of multiple types. Hodge podge of heating systems. Gym uses hanging gas heaters. No gym AC. Windows losing glazing.
<b>River Park North Nature/Science Center</b>	Howard Vainright 252-329-4562	Mon. Closed Sat. 9:30 AM - 5:00 PM Sun. 1:00 PM - 5:00 PM	Tues. - One HVAC unit replaced in 2010. Building 2005 so systems fairly current.

<b>Sports Connection</b>	Ronnie Harris 252-329-4698	Mon.-Fri. 12:00 PM - 9:00 PM 10:00 AM - 5:00 PM 1:00 PM - 5:00 PM	Sat. Sun.	Heat pumps in building. Gym uses hanging furnace heaters, no AC. Constant repairs.
<b>Elm St. Center</b>	Randy Warren 252-329-4269	Mon.-Fri. 2:00 PM - 7:30 PM 9:00 AM - 1:00 PM Closed	Sat. Sun.	Furnace HVAC replaced 2010. New windows; double pane.
<b>River Birch Tennis Center</b>	Chris Hinson 252-329-4170	Mon.-Fri. 9:00 AM - 6:00 PM 10:00 AM - 4:00 PM 1:00 PM - 5:00 PM	Sat. Sun.	Gas pack units. Heat exchanges cracking. Double pane glass.
<b>Teen Center</b>	Ronnie Harris 252-329-4698	Only available by scheduling		3 heat pumps, constantly in repair. Large glass window, single pane.
Bradford Creek Golf Course	Mike Cato; 329-4653	Sunday to Saturday; 8am to dusk.		Units replaced one by one since 2009 as they aged out. One original unit left. Ceiling insulation poor.