



CITY OF GREENVILLE, NC

FIRE/RESCUE



Greenville Fire/Rescue conducts routine and specialized fire inspections on every building within the City and the ETJ, except one and two family residences. These inspections help ensure a fire hazard free environment for your business. By using this checklist, you can avoid common violations.

FIRE INSPECTION CHECKLIST

- ☐ **Fire Extinguishers** – Fire extinguishers have been inspected by a certified extinguisher company.
- ☐ **Combustibles** – Combustibles are properly stored away from heat source.
- ☐ **Extension Cords** – Extension Cords are unplugged and stored away.
- ☐ **Electrical Panels** – There is 3 ft. of clearance in front of each panel.
- ☐ **Exits** – All exits are unobstructed and pathways are clear.
- ☐ **Emergency Lighting and Exit Signs** – All emergency lights and exit signs are operational and unobstructed.
- ☐ **Sprinkler and Fire Alarm Systems** – All systems are in working order and have been tested by a certified sprinkler/alarm system company.

Remember -- Fire Alarms, Sprinkler Systems and Commercial Smoke Alarms need to be tested annually!

For questions call (252) 329-4390

**Dial 9-1-1 for
Emergencies**

Greenville Fire/Rescue • 500 S. Greene Street • PO Box 7207 • Greenville, NC 27834